

MIAMI-DADE WATER & SEWER DEPARTMENT
JOHN E. PRESTON WATER TREATMENT PLANT LABORATORY – CERT. #E 56731
1100 West 2nd Avenue, Miami, Florida 33010
Raymond D. Diaz, Laboratory Services Division Chief – Tel. (786) 552-4738
2015 TYPICAL AVERAGE ANALYSIS
HIALEAH WATER TREATMENT PLANT

PARAMETERS	EXPRESSED IN	MCL ^a	RAW WATER	FINISHED WATER	
METALS					
Aluminum (as Al)	mg/L	b2	0.0	0.0	
Antimony (as Sb)	mg/L	b	0.000	0.000	
Arsenic (as As)	mg/L	b	0.00	0.00	
Barium (as Ba)	mg/L	b	0	0	
Beryllium (as Be)	mg/L	b	0.000	0.000	
Cadmium (as Cd)	mg/L	b	0.000	0.000	
Calcium (as Ca)	mg/L	d	74	18	
Chromium (as Cr)	mg/L	b	0.0	0.0	
Copper (as Cu)	mg/L	c	0.0	0.0	
Iron (as Fe)	mg/L	b2	0.4	0.0	
Lead (as Pb)	mg/L	b	0.000	0.000	
Magnesium (as Mg)	mg/L	d	6.8	4.4	
Manganese (as Mn)	mg/L	b	0.01	0.00	
Mercury (as Hg)	mg/L	b	0.000	0.000	
Nickel (as Ni)	mg/L	b	0.0	0.0	
Potassium (as K)	mg/L	d	2.3	2.6	
Selenium (as Se)	mg/L	b	0.00	0.00	
Silver (as Ag)	mg/L	b2	0.0	0.0	
Sodium (as Na)	mg/L	b	27	31	
Thallium (as Tl)	mg/L	b	0.000	0.000	
Zinc (as Zn)	mg/L	b2	0	0	
ANIONS					
Bromide (as Br ⁻)	mg/L	d	0.12	0.09	
Chlorides (as Cl ⁻)	mg/L	b2	39	43	
Cyanides (as CN ⁻)	mg/L	c	0.00	0.00	
Fluoride (as F ⁻)	mg/L	c	0.20	0.5	
Nitrates (as N)	mg/L	b	0	0	
Nitrites (as N)	mg/L	b	0	0	
Sulfates (as SO ₄ ²⁻)	mg/L	b2	7	7	
PHYSICAL & CHEMICAL PROPERTIES					
Alkalinity (as CaCO ₃)					
Phenolphthalein	mg/L	d	0	7	
Total	mg/L	d	211	63	
Ammonia (as NH ₃)	mg/L	d	0.48	0.27	
Carbon Dioxide (as free CO ₂)	mg/L	d	22	0.13	
Chlorine Residual at Plant (as Cl ₂)	mg/L	b	f	0.0/0.0	0.0/3.54

MIAMI-DADE WATER & SEWER DEPARTMENT
JOHN E. PRESTON WATER TREATMENT PLANT LABORATORY – CERT. #E 56731
1100 West 2nd Avenue, Miami, Florida 33010
Raymond D. Diaz, Laboratory Services Division Chief – Tel. (786) 552-4738
2015 TYPICAL AVERAGE ANALYSIS
HIALEAH WATER TREATMENT PLANT

PARAMETERS	EXPRESSED IN		MCL ^a	RAW WATER	FINISHED WATER
Color	PCU	b2	15	20	3
Conductivity	umhos/cm	d		552	296
Hardness (as CaCO ₃)					
Total	mg/L	d		216	63 =
Non-carbonate	mg/L	d		5	0
Oxygen, dissolved (as O ₂)	mg/L	d		3.5	12.5
pH	pH	c	≥6.5	7.3	9.4
Ortho Phosphate (as PO ₄ ³⁻)	mg/L	d		0.05	0.34
Total Phosphate (as PO ₄ ³⁻)	mg/L	d		0.10	0.49
Silica (as SiO ₂)	mg/L	d		7.64	7.33
Surfactants (MBAS)	mg/L	b2	0.5	0.0	0.0
Temperature	⁰ C	d		25.6	25.4 ∞
Threshold Odor Number	TON	b	3	3	1
Total Dissolved Solids	mg/L	b2	500	338	194
Total Organic Carbon	mg/L	d		7	4
Turbidity	NTU	b	1.0	0.5	0.2
MICROBIOLOGY					
Cryptosporidium/Giardia	#/100L	d, g		ND	--
Total Coliform	Present-Absent -	P, b A	e	--	A
ORGANICS					
Endrin	mg/L	b	0.002	0.000	0.000
Lindane	mg/L	b	0.0002	0.0000	0.0000
Methoxychlor	mg/L	b	0.04	0.00	0.00
Toxaphene	mg/L	b	0.003	0.000	0.000
2, 4, -D	mg/L	b	0.07	0.00	0.00
2, 4, 5 – TP (Silvex)	mg/L	b	0.05	0.00	0.00
Phenols	mg/L	c	0.001	0.000	0.000
Total Trihalomethanes	mg/L	b	0.10	0.00	0.00
VOLATILE ORGANICS					
Vinyl Chloride	mg/L	b	0.001	0.000	0.000
Benzene	mg/L	b	0.001	0.000	0.000
Carbon Tetrachloride	mg/L	b	0.003	0.000	0.000
1, 2- Dichloroethane	mg/L	b	0.003	0.000	0.000
Trichloroethylene	mg/L	b	0.003	0.000	0.000
para-Dichlorobenzene	mg/L	b	0.075	0.000	0.000
1, 1- Dichloroethylene	mg/L	b	0.007	0.000	0.000
1, 1, 1-Trichloroethane	mg/L	b	0.2	0.0	0.0
cis-1, 2 – Dichloroethylene	mg/L	b	0.07	0.00	0.00

MIAMI-DADE WATER & SEWER DEPARTMENT
JOHN E. PRESTON WATER TREATMENT PLANT LABORATORY – CERT. #E 56731
1100 West 2nd Avenue, Miami, Florida 33010
Raymond D. Diaz, Laboratory Services Division Chief – Tel. (786) 552-4738
2015 TYPICAL AVERAGE ANALYSIS
HIALEAH WATER TREATMENT PLANT

PARAMETERS	EXPRESSED IN		MCL ^a	RAW WATER	FINISHED WATER
1, 2- Dichloropropane	mg/L	b	0.005	0.000	0.000
Ethylbenzene	mg/L	b	0.7	0.0	0.0
Monochlorobenzene	mg/L	b	0.1	0.0	0.0
o- Dichlorobenzene	mg/L	b	0.6	0.0	0.0
Styrene	mg/L	b	0.1	0.0	0.0
Tetrachloroethylene	mg/L	b	0.003	0.000	0.000
Toluene	mg/L	b	1	0	0
Trans-1, 2-Dichloroethylene	mg/L	b	0.1	0.0	0.0
Xylenes (total)	mg/L	b	10	0	0
Dichloromethane	mg/L	b	0.005	0.000	0.000
1, 2, 4 – Trichlorobenzene	mg/L	b	0.07	0.00	0.00
1, 1, 2 – Trichloroethane	mg/L	b	0.005	0.000	0.000
Ethylene Dibromide	mg/L	b	0.00002	0.00000	--
RADIONUCLIDES					
Gross Alpha	pCi/L	b	15	<1.65	<1.4
Radon	pCi/L	d	--	415	<64
Radium 226 plus 228	pCi/L	b	5	--	<1.5

NOTES

- a) MCL – Maximum Contaminant Level. Values are for the Agency with the most stringent levels.
- b) MCL – Set by Florida Administrative Code Chapter 62-550, Primary Drinking Water Standards.
- b2) MCL – Set by Florida Administrative Code Chapter 62-550, Secondary Drinking Water Standards.
- c) MCL – Set by Dade County Code 24-43.3 for Drinking Water.
- d) No Limits Set
- e) No more than 5.0 percent of the samples collected during a month show the presence of total coliform bacteria.
- f) For free chlorine residual: minimum is 0.2 mg/L, maximum is 4.0 mg/L. For total chlorine residual: minimum is 0.6 mg/L, maximum is 4.0 mg/L. Results expressed as free/total.
- g) ND - Not Detected.
- + NOD - Not Detected.
- ❖ < Less than.
- ❖ ≥ Greater than or equal to.
- ❖ = 3.7 grains per gallon.
- ❖ ∞ 77.7°F